

SAP 2009 / FIT November 1st 2012

Payback Calculations for Solar PV Systems

Energy Rating Data

Assumed annual rate of inflation	4.60%
Annual increase in energy cost	9.0%
Percentage of export	50%
Percentage of self consumption	70%
Annual Drop in system efficiency	0.5%
Imported electricity cost p/kwh	14

SAP Details

Roof Orientation	South
Roof Pitch	30°
Overshadowing	0 or very little <20%
EPC efficiency rating	EPC Cert =>D
Number of Panels	12
Size of Panels (Watt)	240

Drop your Logo here

% Return on investment APR over 20 years (on FIT income)

8.57%

SOLAR PV SYSTEM PRICE

£6,125.00

inc VAT

FIT rate p/kWh

15.44

IT export rate p/kwh

4.5

System Size kWp

2.88

kWh / Year

2,472

CO ₂ Emission Savings kgCO ₂	Benefit over 20 years	kWh/annum	FIT Rate (Inc Inflation)	FIT Annual income	Cost of Electricity	Saving on Electricity Used	Export FIT Rate (Inc Inflation)	Export FIT revenue	Savings and Income per	Cumulative Benefit
1,296.91	Year 1	2472 kWh	15.44 p/kWh	£381.71	14.00 p/kWh	£242.27	4.5 p/kWh	£55.62	£679.61	£679.61
1,290.43	Year 2	2460 kWh	16.15 p/kWh	£397.27	15.26 p/kWh	£262.76	4.7 p/kWh	£57.89	£717.92	£1,397.53
1,283.98	Year 3	2448 kWh	16.89 p/kWh	£413.47	16.63 p/kWh	£284.98	4.9 p/kWh	£60.25	£758.69	£2,156.22
1,277.56	Year 4	2435 kWh	17.67 p/kWh	£430.32	18.13 p/kWh	£309.07	5.2 p/kWh	£62.71	£802.10	£2,958.32
1,271.17	Year 5	2423 kWh	18.48 p/kWh	£447.87	19.76 p/kWh	£335.20	5.4 p/kWh	£65.27	£848.33	£3,806.65
1,264.81	Year 6	2411 kWh	19.33 p/kWh	£466.13	21.54 p/kWh	£363.54	5.6 p/kWh	£67.93	£897.60	£4,704.25
1,258.49	Year 7	2399 kWh	20.22 p/kWh	£485.13	23.48 p/kWh	£394.28	5.9 p/kWh	£70.70	£950.11	£5,654.36
1,252.20	Year 8	2387 kWh	21.15 p/kWh	£504.91	25.59 p/kWh	£427.62	6.2 p/kWh	£73.58	£1,006.10	£6,660.46
1,245.93	Year 9	2375 kWh	22.13 p/kWh	£525.49	27.90 p/kWh	£463.77	6.4 p/kWh	£76.58	£1,065.84	£7,726.30
1,239.70	Year 10	2363 kWh	23.14 p/kWh	£546.92	30.41 p/kWh	£502.98	6.7 p/kWh	£79.70	£1,129.60	£8,855.91
1,233.51	Year 11	2351 kWh	24.21 p/kWh	£569.22	33.14 p/kWh	£545.51	7.1 p/kWh	£82.95	£1,197.68	£10,053.58
1,227.34	Year 12	2340 kWh	25.32 p/kWh	£592.42	36.13 p/kWh	£591.63	7.4 p/kWh	£86.33	£1,270.39	£11,323.97
1,221.20	Year 13	2328 kWh	26.49 p/kWh	£616.58	39.38 p/kWh	£641.66	7.7 p/kWh	£89.85	£1,348.08	£12,672.06
1,215.10	Year 14	2316 kWh	27.71 p/kWh	£641.71	42.92 p/kWh	£695.91	8.1 p/kWh	£93.51	£1,431.14	£14,103.19
1,209.02	Year 15	2305 kWh	28.98 p/kWh	£667.88	46.78 p/kWh	£754.75	8.4 p/kWh	£97.33	£1,519.95	£15,623.15
1,202.98	Year 16	2293 kWh	30.31 p/kWh	£695.11	50.99 p/kWh	£818.56	8.8 p/kWh	£101.29	£1,614.96	£17,238.11
1,196.96	Year 17	2282 kWh	31.71 p/kWh	£723.45	55.58 p/kWh	£887.77	9.2 p/kWh	£105.42	£1,716.64	£18,954.75
1,190.98	Year 18	2270 kWh	33.17 p/kWh	£752.94	60.59 p/kWh	£962.83	9.7 p/kWh	£109.72	£1,825.50	£20,780.25
1,185.02	Year 19	2259 kWh	34.69 p/kWh	£783.64	66.04 p/kWh	£1,044.24	10.1 p/kWh	£114.20	£1,942.07	£22,722.32
1,179.10	Year 20	2248 kWh	36.29 p/kWh	£815.59	71.98 p/kWh	£1,132.53	10.6 p/kWh	£118.85	£2,066.97	£24,789.29
24,742.36		47164 kWh		£11,457.73		£11,661.88		£1,669.68	£24,789.29	
									TOTAL Benefit over 20 years	£24,789.29

* The performance of solar PV systems is impossible to predict with certainty due to the variability in the amount of solar radiation (sunlight) from location to location and from year to year. This estimate is based upon the Government's standard assessment procedure for energy rating of buildings (SAP) and is given as guidance only. It should not be considered as a guarantee of performance.